

**City of Alexandria, Virginia
FY 2023 Proposed Operating Budget & CIP
Budget Questions & Answers**

March 28, 2022

Question: Can you provide more information on the necessity of the Warwick Pool replastering project currently funded in the FY 2023 CIP? Is this regular preventative maintenance or a defect in a brand-new facility?

Response:

Pool replastering is part of industry standard pool maintenance and typically occurs every 5-10 years depending on environmental conditions and general wear and tear. The pool plaster work at Warwick Pool was completed in 2017 as part of the facility replacement. The City's pool contractor assessed the facility last year and noted that replastering was required. City staff reviewed the pool condition and concurred with the contractor's determination.